

Certificate



Reference No. 703086

Conduit for electrical installations

Type designation 16, 20, 25, 32, 40, 50

Certificate holder **PIPELIFE SVERIGE AB**
Produktion Ölsremma
51484 Ölsremma
SWEDEN

The product complies with the standard(s) EN 61386-21:2004

Date of expiry 29 March 2012

EU Directive information *The product satisfies the provisions for CE marking according to the Low Voltage Directive 2006/95/EC.*

Terms in Intertek Semko's Agreement on certification. Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification *Place* Kista - Stockholm

Signed


Niklas Larsson

Date 29 March 2007

STE



Appendix

Reference No. 703086

Technical data

Type designation 16
Classification 34411265-010
Temperature range -25/60°C
Product information Ytterdiam. 16 mm.

Type designation 20
Classification 34411265-010
Temperature range -25/60°C
Product information Ytterdiam. 20 mm.

Type designation 25
Classification 34411265-010
Temperature range -25/60°C
Product information Ytterdiam. 25 mm.

Type designation 32
Classification 34411265-010
Temperature range -25/60°C
Product information Ytterdiam. 32 mm.

Type designation 40
Classification 34411265-010
Temperature range -25/60°C
Product information Ytterdiam. 40 mm.

Type designation 50
Classification 34411265-010
Temperature range -25/60°C
Product information Ytterdiam. 50 mm.



Appendix

Reference No. 703086

Manufacturing site(s) PIPELIFE SVERIGE AB
Produktion Ölsremma
51484 Ölsremma
SWEDEN

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 2006/95/EC.

Certification Body

Intertek Semko AB, Product Certification

Place Kista - Stockholm

Signed


Niklas Larsson

Date 29 March 2007