

# DIN-DVGW type examination certificate

**NW-6203BP5493**

registration number

<b>field of application</b>	products of water supply
<b>distributor</b>	VAG-Armaturen GmbH Carl-Reuther-Straße 1, D-68305 Mannheim
<b>product category</b>	valves for water supply : gate valve (6203)
<b>product description</b>	gate valve for drinking water supply
<b>model</b>	EKO plus
<b>test reports</b>	mechanical test: KT 011/10 from 17.06.2010 (TZW) mechanical test: A0 033/10 from 26.10.2010 (TZW) KTW testing: 200A06_2 from 06.09.2006 (TZW) hygienic testing: W-148264-07-SI from 15.02.2007 (TZW) KTW testing: KA 244/10 from 22.09.2010 (TZW) hygienic testing: MO 190A/07 from 23.10.2005 (TZW)
<b>basis of type examination</b>	DVGW W 363 (01.06.2010) DIN EN 1074-1 (01.07.2000) DIN EN 1074-2 (01.07.2000) BGA KTW (07.01.1977) DVGW W 270 (01.11.2007)
<b>date of expiry / file no.</b>	21.02.2015 / 10-0156-WNV

01.12.2010 GIC-1/2

date, issued by, sheet, head of certification body

DVGW CERT GmbH - accredited by Deutsche Akkreditierungsstelle Technik (DATech) in the TGA GmbH for conformity assessment of products of gas and water supply



DVGW CERT GmbH  
Josef-Wirmer-Straße 1-3  
53123 Bonn

Telefon: +49 228 91 88-888  
Telefax: +49 228 91 88-993  
eMail: info@dvgw-cert.com

DAT-ZE-009/96-02

<b>type</b>	<b>technical data</b>	<b>remarks</b>
EKO plus	pressure rating: PN 10/16 nominal diameter: DN 40	
EKO plus	nominal pressure rating: PN 10/16 nominal diameter: DN 50	
EKO plus	nominal pressure rating: PN 10/16 nominal diameter: DN 65	
EKO plus	nominal pressure rating: PN 10/16 nominal diameter: DN 80	
EKO plus	nominal pressure rating: PN 10/16 nominal diameter: DN 100	
EKO plus	nominal pressure rating: PN 10/16 nominal diameter: DN 125	
EKO plus	nominal pressure rating: PN 10/16 nominal diameter: DN 150	
EKO plus	nominal pressure rating: PN 10/16 nominal diameter: DN 200	
EKO plus	nominal pressure rating: PN 10/16 nominal diameter: DN 250	
EKO plus	nominal pressure rating: PN 10/16 nominal diameter: DN 300	
EKO plus	nominal pressure rating: PN 10/16 nominal diameter: DN 350	
EKO plus	nominal pressure rating: PN 10/16 nominal diameter: DN 400	
EKO plus	nominal pressure rating: PN 10/16 nominal diameter: DN 500	

**hints of utilization / remarks**

With the following test reports it is proven, that the requirements according the standard DVGW W270 (01.11.2007) appendix A.1.1: "Material for the standard application in contact with potable water" are fulfilled:  
W-148264-07-SI, date: 26.04.2006 (WHY)  
040A06\_2, date: 26.10.2006 (TZW)

The logo for DVGW (Deutscher Verein des Gas- und Wasserfaches) is located in the bottom right corner of the page. It consists of the letters 'DVGW' in a bold, sans-serif font, with a stylized graphic element to the right.