PIPELIFE
always part of your life

DECLARATION OF CONFORMITY

No. 2021-02-09-44

Product name: PVC-U cable shelters

Product identification element: SFS 5608 PVC-U A

Product technical regulation: SFS 5608:1990 Cable shelter for underground laying. Construction and testing requirements.

Product application area: Cable shelter for underground laying.

Declared product properties	Unit	Value	Method
Material	-	PVC-U	SFS 5608:1990
Nominal outside diameter	mm	100	
Strength class	-	A	
Ring stiffness S_{tk}	kN/m^2	≥ 16	
Impact resistance at -10 °C, B50	mm	> 900	SFS 3435:1981

Manufacturer: Pipelife Eesti AS
Põrguvälja tee 4, Lehmja, Rae vald, Harjumaa 75306, Estonia

Place of manufacturing: Pipelife Eesti AS
Põrguvälja tee 4, Lehmja, Rae vald, Harjumaa 75306, Estonia

With this declaration of conformity Pipelife Eesti AS declares that the products conform to the requirements as stated in above mentioned product technical regulations and declared product properties.
Pipelife Eesti AS holds the product certificate no 2103826 issued by Bureau Veritas Eesti OÜ assuring that above mentioned products conform to the above mentioned requirements.
Pipelife Eesti AS holds the certificate of conformity no Q-066-21 issued by Inspecta Estonia OÜ assuring that the quality management system of Pipelife Eesti AS conforms to the requirements of the standard ISO 9001:2015.
Pipelife Eesti AS holds the certificate of conformity no Q-065-21 issued by Inspecta Estonia OÜ assuring that the environmental management system of Pipelife Eesti AS conforms to the requirements of the standard ISO 14001:2015.

Issue date: 9th of February 2021

Signed by:
Lembit Salla
Pipelife Eesti AS Plant Manager

kiwa certified
ISO 9001
ISO 14001
Inspecta Estonia OÜ